

SANTA  MONICA

Building and Safety
(310) 458-8355

1685 Main Street, P.O. Box 2200
Santa Monica, CA 90407-2200

June 11, 1997

Mr. Gary Oelze
A.C. Energy Systems, Inc.
224 Birmingham Drive, Ste. 142
Cardiff, CA 92007

Dear Mr. Oelze,

This letter is in response to our telephone conversation this morning and your letter of May 29, 1997.

You requested information on the City of Santa Monica's clarification of the code requirements for ventilation of enclosed garages.

Santa Monica enforces the Uniform Building Code and requires that if the ventilation system is not modulated by carbon monoxide sensing devices, then, it must remain on continuously.

Thank you for your interest in code compliance. If I can be of further assistance, please feel free to call me.

Sincerely,



Mario J. Fala
Senior Mechanical Inspector
(310) 458-8355

cc: Nagy Jacob
File